

Manufacturer's declaration on fire tests carried out with the
200 Series Product Family - Version 02

Issued by:	Wilh. Schlechtendahl & Söhne GmbH & Co. KG Hauptstraße 18-32 42579 Heiligenhaus
Additions to the instructions:	ma_K0200577_Rohrrahmenschloss_Serie200_ Kurzanleitung_DE_GB ma_K0200510_Rohrrahmenschloss_Serie200_DE_GB ma_K0200552_Panik Rohrrahmenschloss_Serie200_ Kurzanleitung_DE_GB ma_K0200388_Panik_Rohrrahmenschloss_Serie200_DE _GB

This manufacturer's declaration applies to the following lock and fitting designs in the tubular frame area:

- **Locks without panic function of series 200**
14.110..., 14.140..., 14.144..., 14.146..., 14.156..., 14.158...
- **Locks with panic function of series 200**
14.160..., 14.162..., 14.164..., 14.166..., 14.168..., 14.170..., 14.172..., 14.174...,
14.176..., 14.178..., 14.180..., 14.182..., 14.145..., 14.159...
- **Self-locking-Locks with panic function of series 200**
14.250..., 14.252..., 14.254..., 14.256..., 14.260..., 14.262..., 14.264..., 14.266...,
14.270..., 14.272..., 14.274..., 14.276...
- **Counter-Strike-Boxes of series 200**
14.280..., 14.284..., 14.285...
- **Panic fittings of series 200**
Panic bar handle 14.4xx.0..., 14.4xx.1..., 14.4xx.2..., 14.4xx.3...
Panic push bar 14.484..., 14.492...
- **Complementary accessories**
z.B. Latch 12mm, Latch 12/16mm, Top lock, Latch spring loaded, Connecting rods,
Rod guides, Strike plates in different versions

List of fire tests

Item	1	2
Profile system	Steel profile insulated	Steel profile not insulated
Door structure	2-leaf swing door	2-leaf swing door
Which side was tested?	Hinge and opposite hinge side	Opposite hinge side
Achieved classification	EI 60/ E90	E60
Test report number	DMT-DO-50-399/423	DMT-DO-50-690-R1

Pos.	3
Profile system	Steel profile not insulated
Door structure	1-leaf swing door
Which side was tested?	Hinge and opposite hinge side
Achieved classification	E30
Test report number	DMT-DO-50-397

Basis of this manufacturer's declaration

Fire tests carried out in recognized test centers according to the previous listing.



Andreas Mielke, certified technician
CE-Commissioner

Heiligenhaus, 27.04.2023

(Place and date of issue)