

## Manufacturer's declaration on fire tests carried out with the 200 Series Product Family - Version 03

**Issued by:** Wilh. Schlechtendahl & Söhne GmbH & Co. KG  
Hauptstraße 18 32  
42579 Heiligenhaus

### **Additions to the instructions:**

- ma\_K0200765\_Rohrrahmenschloss\_Serie200\_Kurzanleitung\_DE\_GB
- ma\_K0200766\_Rohrrahmenschloss\_Serie200\_DE\_GB
- ma\_K0200747\_Panik-Rohrrahmenschloss\_Serie200\_Kurzanleitung\_DE\_GB
- ma\_K0200746\_Panik-Rohrrahmenschloss\_Serie200\_DE\_GB

**This manufacturer's declaration applies to the following lock and fitting designs in the tubular frame area:**

- **Locks without panic function of series 200**  
14.110..., 14.140..., 14.144..., 14.146..., 14.156..., 14.158...
- **Locks with panic function of series 200**  
14.160..., 14.162..., 14.164..., 14.166..., 14.168..., 14.170..., 14.172..., 14.174...,  
14.176..., 14.178..., 14.180..., 14.182..., 14.145..., 14.159...
- **Self-locking-Locks with panic function of series 200**  
14.250..., 14.252..., 14.254..., 14.256..., 14.260..., 14.262..., 14.264..., 14.266...,  
14.270..., 14.272..., 14.274..., 14.276...
- **Counter-Strike-Boxes of series 200**  
14.280..., 14.284..., 14.285...
- **Panic fittings of series 200**  
Panic bar handle 14.4xx.0..., 14.4xx.1..., 14.4xx.2..., 14.4xx.3...  
Panic push bar 14.484..., 14.492...
- **Complementary accessories**  
z.B. Latch 12mm, Latch 12/16mm, Top lock, Latch spring loaded, Connecting rods,  
Rod guides, Strike plates in different versions

**List of fire tests**

Item	1	2
<b>Profile system</b>	Steel profile insulated	Steel profile not insulated
<b>Door structure</b>	2-leaf swing door	2-leaf swing door
<b>Which side was tested?</b>	Hinge and opposite hinge side	Opposite hinge side
<b>Achieved classification</b>	EI 60/ E90	E60
<b>Test report number</b>	DMT-DO-50-399/423	DMT-DO-50-690-R1

Pos.	3
<b>Profile system</b>	Steel profile not insulated
<b>Door structure</b>	1-leaf swing door
<b>Which side was tested?</b>	Hinge and opposite hinge side
<b>Achieved classification</b>	E30
<b>Test report number</b>	DMT-DO-50-397

**Basis of this manufacturer's declaration**

Fire tests carried out in recognized test centers according to the previous listing.




---

Andreas Mielke, certified technician  
CE-Commissioner

Heiligenhaus, 15.05.2024

(Place and date of issue)