SKG-IKOB PRODUCTCERTIFICATE 478.211.02

Date of issue: 28-06-2017





Certificate holder

Wilh. Schlechtendahl & Söhne GmbH & Co KG

Hauptstraße 18-32 42579 Heiligenhaus

T: +49 (0) 2056 170 E: wss@wss.de

I: www.wss.de

Declaration of SKG-IKOB

This certificate has been issued on the basis of BRL 3104 in accordance with the SKG-IKOB Regulations for Attestation, Certification and Inspection.

SKG-IKOB declares that the by or on behalf of the certificate owner produced building hardware product:

multipoint profile lock with keepers

delivered under logo / brand:

WSS

delivered under type- and / or article number:

meets class 2 STER according BRL 3104 and NEN 5089: 2009 if the product is indelibly marked with the SKG mark, as shown above.

For SKG-IKOB

ir. H.A.J. van Dartel Certification manager

Verify at www.sterrenwijzer.nl if this certificate is still valid and actual. This certificate contains 2 pages.

SKG-IKOB Certificatie Poppenbouwing 56 4191 NZ Geldermalsen

Postbus 202 4190 CE Geldermalsen

T 088-2440100 info@skgikob.nl www.skgikob.nl

SKG-IKOB PRODUCTCERTIFICATE

Wilh. Schlechtendahl & Söhne GmbH & Co KG

Number: 478.211.02 page 2 of 2

1. PRODUCT TYPE multipoint profile lock with keepers PRODUCT TYPE multipoint lock

2. TECHNICAL SPECIFICATION

Operating: Mechanical operation

Construction: 1 forend with main lock with turning bolt and var. type latches+ 2 or 4 additional pen-hook bolts + 1 keeperplate

for main lock and 2 or 4 keeperplates for pen-hook bolts

System: key operated; lockable by 17 mm profile cylinder; PZ: 92 mm; BS: 25 to 40 mm

Material: forend and keeper plates: inox, lock cases: steel zinc coated

Dimension: forend: 1800x20/22/24x3 mm; lock cases: 250xBS+17x17,5 / 150x41x17,5 mm; keeperstrip for mainlock:

230x20/22/24x3 mm; keeperstrip for hooke bolts: 145x20/22/24x3 mm

Fixing: forend and keeper plates: M5 bolts in M5 insert nuts

Intended use: metal, door-inward-opening, door-outward-opening

for metal doors

3. DELIVERY

The delivery includes an installation instruction:

K0200469 03/2017 online: 80826_02.03/2017 + tek: 80826

4. PERFORMANCES

A multipoint profile lock with keepers according this certificate fulfils the relevant requirements of BRL 3104.

A window- or door set, in which this multipoint profile lock with keepers is installed according the installation instructions of the certificate holder meets at least burglar resistance class (RC) 2 of NEN 5096 and EN 1627, if:

the façade element or the (profile-)system from which the element is manufactured is delivered under a (KOMO-)quality approval with
respect to the aspect burglar resistance, in which the actual window or door type is admitted and the herein mentioned conditions are
fulfilled.

A window or door, in existing buildings, in which this multipoint profile lock with keepers is installed according the installation instructions of the certificate holder, meets the requirements of the Police Mark Save Housing (PKVW) - Existing Building, if:

• the other aspects of the façade element also comply with the applicable PKVW Protection directive (publication CCV).