

SKG-IKOB PRODUCTCERTIFICATE

478.632.01

Date of issue: 08-07-2024



Certificate holder

Wilh. Schlechtendahl & Söhne GmbH & Co KG
Hauptstraße 18-32
42579 Heiligenhaus
T: +49 (0) 2056 170
E: wss@wss.de
I: www.wss.de



Declaration of SKG-IKOB

This certificate has been issued on the basis of BRL 3104 in accordance with the SKG-IKOB Regulations for Attestation, Certification and Inspection.

SKG-IKOB declares that the by or on behalf of the certificate owner produced building hardware product:

backplate narrow

delivered under logo / brand:

WSS

delivered under type- and / or article number:

5000 9947 , 5000 9949

meets class 3 STER according BRL 3104 and NEN 5089: 2009 if the product is indelibly marked with the SKG mark, as shown above.

For SKG-IKOB

A handwritten signature in blue ink, consisting of a stylized 'H' and 'A' followed by a horizontal line.

ir. H.A.J. van Dartel
Certification manager

Verify at www.sterrenwijzer.nl if this certificate is still valid and actual.
This certificate contains 2 pages.

SKG-IKOB Certificatie
Poppenbouwing 56
4191 NZ Geldermalsen

Postbus 202
4190 CE Geldermalsen

T 088-2440100
info@skgikob.nl
www.skgikob.nl

CERTIFICATE

SKG-IKOB PRODUCTCERTIFICATE

Wilh. Schlechtendahl & Söhne GmbH & Co KG
Number: 478.632.01

page 2 of 2

1. PRODUCT
backplate narrow

PRODUCT TYPE
security furniture

2. TECHNICAL SPECIFICATION

Operating:	Mechanical operation
Construction:	1 set of an outside part and an inside part with mounting screws
System:	various cylinder holes various handles
Material:	outside and inside part: inox
Dimension:	outside part: 258x33x12 mm inside part: 258x33x10 mm
Fixing:	3xM6 (10.9) in steel cams c.t.c. 107/114
Intended use:	wood, PVC, metal in combination with mortice locks on doors

3. DELIVERY

The preconditions for correct installation and the fasteners to be used are described in the enclosed or digitally published installation instructions with the following version:
K0200469 03/2017 online: 80826_02.03/2017 + tek: 80826

4. PERFORMANCES

A backplate narrow according this certificate fulfils the relevant requirements of BRL 3104.

A window- or door set, in which this backplate, narrow is installed according the installation instructions of the certificate holder meets at least burglar resistance class 3 of NEN 5096 and RC 2N of EN 1627, if:

the façade element or the (profile-)system from which the element is manufactured is delivered under a (KOMO-)quality approval with respect to the aspect burglar resistance, in which the actual window or door type is admitted and the herein mentioned conditions are fulfilled.

A window or door, in existing buildings, in which this backplate, narrow is installed according the installation instructions of the certificate holder, meets the requirements of the Police Mark Save Housing (PKVW) - Existing Building, if:

the other aspects of the façade element also comply with the applicable PKVW Protection directive (publication CCV).
