

# SKG-IKOB PRODUCTCERTIFICATE

## 478.651.02

Date of issue: 28-06-2017



### Certificate holder

Wilh. Schlechtendahl & Söhne GmbH & Co KG  
Hauptstraße 18-32  
42579 Heiligenhaus  
T: +49 (0) 2056 170  
E: wss@wss.de  
I: www.wss.de



### Declaration of SKG-IKOB

This certificate has been issued on the basis of BRL 3104 in accordance with the SKG-IKOB Regulations for Attestation, Certification and Inspection.

SKG-IKOB declares that the by or on behalf of the certificate owner produced building hardware product:

**rim cam barrel hinge with fixed axe**

delivered under logo / brand:

**WSS**

delivered under type- and / or article number:

**04.032.xxxx.xxx**

meets class 2 STER according BRL 3104 and NEN 5089: 2009 if the product is indelibly marked with the SKG mark, as shown above.

For SKG-IKOB

A blue ink handwritten signature, appearing to be "H.A.J. van Dartel", written over a light blue horizontal line.

ir. H.A.J. van Dartel  
Certification manager

Verify at [www.sterrenwijzer.nl](http://www.sterrenwijzer.nl) if this certificate is still valid and actual.  
This certificate contains 2 pages.

SKG-IKOB Certificatie  
Poppenbouwing 56  
4191 NZ Geldermalsen

Postbus 202  
4190 CE Geldermalsen

T 088-2440100  
[info@skgikob.nl](mailto:info@skgikob.nl)  
[www.skgikob.nl](http://www.skgikob.nl)

CERTIFICATE

# SKG-IKOB PRODUCTCERTIFICATE

Wilh. Schlechtendahl & Söhne GmbH & Co KG  
Number: 478.651.02

page 2 of 2

## 1. PRODUCT

rim cam barrel hinge with fixed axe

## PRODUCT TYPE

hinge

## 2. TECHNICAL SPECIFICATION

Operating:	N.A.
Construction:	2 frame-parts and 1 leaf-part
System:	rim
Material:	frame and leaf part: aluminium coated or anodised ; pen: inox
Dimension:	frame-part 2X: 48/75x43x39/52 mm; leaf-part: 76/89x43x39/52 mm
Fixing:	frame and leaf part, per part: 2 x M8 inox one way in zamak installation ancre ; dim: various length x19x12 mm or with inox ancre bolts Ø 12 mm, door min. 2 profile sheets
Intended use:	metal, door-inward-opening, door-outward-opening inside and outside opening aluminium doors and windows

## 3. DELIVERY

The delivery includes an installation instruction:  
K0101494 11/2016 + K0200469 03/2017 online:80826\_01 03/2017 + tek: 80826

## 4. PERFORMANCES

A rim cam barrel hinge with fixed axe according this certificate fulfils the relevant requirements of BRL 3104.

A window- or door set, in which this rim cam barrel hinge with fixed axe is installed according the installation instructions of the certificate holder meets at least burglar resistance class (RC) 2 of NEN 5096 and EN 1627, if:

- the façade element or the (profile-)system from which the element is manufactured is delivered under a (KOMO-)quality approval with respect to the aspect burglar resistance, in which the actual window or door type is admitted and the herein mentioned conditions are fulfilled.

A window or door, in existing buildings, in which this rim cam barrel hinge with fixed axe is installed according the installation instructions of the certificate holder, meets the requirements of the Police Mark Save Housing (PKVW) - Existing Building, if:

- the other aspects of the façade element also comply with the applicable PKVW Protection directive (publication CCV).