

Materialprüfungsamt Nordrhein-Westfalen

Prüfen • Überwachen • Zertifizieren

Certificate of constancy of performance**0432-CPR-00037-03**

Version 01

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

WSS door coordinator

Door coordinator for double leaf doors as detailed on appendix 2
placed on the market under the name or trade mark of

Wilh. Schlechtendahl & Söhne GmbH & Co. KG

Hauptstraße 18-32
42579 Heiligenhaus
Deutschland

and produced in the manufacturing plant(s)

DO 18.4

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standard(s)

EN 1158:1997/A1:2002/AC:2006

under **system 1** for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 26.09.2016 and will remain valid until 26.09.2021 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Dortmund, 07.03.2019



Friedrich
Head of Certification Body

This Certificate consists of 1 page and 2 annex(es).

The original of this document was issued in German language.
In case of doubt only the German version is valid.



Door coordinator devices WSS**manufacturing plants**

product	production plant
Door coordinator devices	WSS Wilh. Schlechtendahl & Söhne GmbH & Co. KG Hauptstrasse 18-32 42579 Heiligenhaus DO 18.4

List of products

Type : 05.650.3010.010/05.650.3510.010
Description : separate mounted door coordinator,
fixed on the frame with telescopic arm to be used on DIN left and DIN
right door leafs, adjusting screw for subsequent tolerance compensation,
with stop brackets and installation accessories.
design:
steel zinc coated, round tube telescopic arm
Installation : fixing on the frame, the stop brackets are mounted on the door leafs
Size : 3-7
Classification : 3 5 7/3 1 1 3
Remarks : Carry bar 05.670.0000.010 for overhead and floor concealed door closers
Carry bar 05.671.0000.010 for integrated door closers

Type : 05.650.3020.010/05.650.3520.010
Description : separate mounted door coordinator,
fixed on the frame with telescopic arm to be used on DIN left and DIN
right door leafs, adjusting screw for subsequent tolerance compensation,
with stop brackets and installation accessories.
design:
steel zinc coated, square tube telescopic arm
30 mm and 35 mm distance of stop brackets from the door leaf
Installation : fixing on the frame, the stop brackets are mounted on the door leafs
Size : 3-7
Classification : 3 5 7/3 1 1 3
Remarks : Carry bar 05.670.0000.010 for overhead and floor concealed door closers
Carry bar 05.671.0000.010 for integrated door closers

Materialprüfungsamt Nordrhein-Westfalen

Prüfen · Überwachen · Zertifizieren

Intended use:

For single- and double leaf fire- and/or smoke protection doors

Essential properties	Clauses with requirements in EN 1158:1997/A1:2002/AC:2006	Performance of the product
Self-closing	5.1.2 Completeness of the products	passed
	5.1.3 Correct closing sequence	passed (Size 3-7)
	5.2.1 General	
	5.2.2 Overload behaviour in closing direction	passed (Size 3-7)
	5.2.3 Manipulation	passed (Size 3-7)
	5.2.4 Resistance in waiting position	passed (Size 3-7)
Durability Self-closing	5.2.6 Damage	passed (Size 3-7)
	5.2.8 Use on fire-/ smoke protection doors	passed (Class 1)
	5.2.5 Durability	Class 5 (50.000 Cycles): passed
	5.2.7 Corrosion resistance	
	5.2.7.1	Class 3 (96h): passed
	5.2.7.2	Class 3 (96h): passed
	5.2.7.3	Class 3 (96h): passed
Dangerous substances	Annex ZA.3	The manufacturer has not declared any dangerous substances.